Evidence of Performance

Airborne sound insulation of building elements

Test report 163 34476/Z2e

This is a translation of the test report 163 34476/Z2 of 15th November 2007.



Client

Press Glas S.A. Nowa Wies Kopalniana 9

42-262 Poczesna Poland

Product Isolation glass unit

Designation Float 8 mm / 16 / 44.2 Thermofloat Ar.

Size (w × h) 1230 mm × 1480 mm

Construction 8/16/8 LG

Gas filling Argon

Area related weight 39,9 kg/m²

Weighted sound reduction index R_w Spectrum adaptation terms C and C_{tr}




 $R_w(C; C_{tr}) = 37 (-2;-5) dB$

Basis

EN ISO 140-1:1997+A1:2004 EN 20140-3 :1995+A1:2004 EN ISO 717-1 : 1996+A1:2006

Representation



Informations for use

This test report may be used to validate the sound reduction of a building element.

Validity for germany:

 R_{w} corresponds to $R_{w,\text{P}}$ for DIN 4109 Annex 1 table 40

Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

Notes on publication

The **ift** Guidance Sheet "Conditions and Guidance for the use of **ift** Test Documents" applies.

The cover sheet can be used as a summary.

Contents

This test report includes 6 pages

- Test specimen
- Test procedure
- 3 Test results
- 4 Instructions for use Data sheet (1 page)

ift Rosenheim 22nd November 2007

Special items

Dr. Joachim Hessinger, Dipl.-Phys. Head of test laboratory ift centre for acoustic

Bernd Saß, Dipl.-Ing. (FH) vice head of test laboratory ift centre for acoustic



Lackermannweg 26 D-83071 Stephanskirchen

Tel. +49 (0)8036/3006-0 Fax: +49 (0)8036/3006-33 www.lsw-gmbh.de Sitz: 83026 Rosenheim AG Traunstein, HRB 14822

Sparkasse Rosenheim Kto. 500 435 805 BLZ 711 500 00