

Evidence of Performance

Airborne sound insulation of building elements

Test report 163 42018/2e

This is a translation of the test report 163 42018/2 of 11th December 2009.




Client **Press Glas S.A.**
Nowa Wies
Kopalniana 9

42-262 Poczesna
Poland

Basis

EN ISO 140-1:1997+A1:2004
EN 20140-3 :1995+A1:2004
EN ISO 717-1 : 1996+A1:2006

Representation



Product	Insulating glass unit
Designation	Float 10mm+24+44.2 Thermofloat kl.P2A.Ar
Size (w x h)	1230 mm x 1480 mm
Construction	10/24/8 LSG
Gas filling	Argon
Area related weight	45,4 kg/m ²
Special items	-/-

Informations for use

This test report may be used to validate the sound insulation of a building element.

Validity for germany:

R_w corresponds to R_{w,F} for DIN 4109 Annex 1 table 40.

Weighted sound reduction index R_w
Spectrum adaptation terms C and C_{tr}



$$R_w (C; C_{tr}) = 42 (-1; -4) \text{ dB}$$

Validity

The data and results given relate solely to the described, tested object.

Testing the acoustic properties does not allow any statement to be made on further characteristics of the present structure which could define performance and quality.

Notes on publication

The ift Guidance Sheet "Conditions and Guidance for the use of ift Test Documents" applies.

The cover sheet can be used as a summary.

ift Rosenheim
07 January 2010

Dr. Joachim Hessinger, Dipl.-Phys.
Head of Testing Department
ift Centre for Acoustics

Bernd Saß, Dipl.-Ing. (FH)
Assistant Head of Testing Department
ift Centre for Acoustics

Contents

This test report includes 6 pages

- 1 Test specimen
 - 2 Test procedure
 - 3 Test results
 - 4 Instructions for use
- Data sheet (1 page)

